ELECTRICAL - KEYNOTED LEGEND	
Key Value	Keynote Text
2E	PROVIDE OWNER CAPABLE METERING FOR PANELS L2A, H2A & H2M, SUCH AS AN EMON-DMON STYLE.
3E	PROVIDE TOTAL PROTECTION SOLUTIONS SURGE SUPPRESION WITH TRANSIENT FILTER #TK-LP120-3Y480-L-F AT ALL LIGHTING PANELS.
4E	PROVIDE INTERFACE WITH DATA (CAT-6), COAX, HDMI, SOUND SYSTEM, DVD PLAYER AND ANY ADDITIONAL INTERFACES GCPLD MIGHT REQUIRE. COORDINATE WITH GCPLD.
5E	PROVIDE CARD READER ACCESS TO GCPLD SPACE.
6E	PROVIDE A JUNCTION BOX FOR POWERING THE SHADES FOR THE SPACE. LOW VOLTAGE SHADE SWITCHES LOCATED ADJACENT TO LIGHT SWITCH LOCATIONS. COORDINATE WITH SUPPLIER PRIOR TO ROUGH-IN.



GENERAL DRAWING NOTES:

1. THERE ARE EXISTING FIRE ALARM DEVICES IN THE SPACE TO BE REUSED. RELOCATE THE EXSITING DEVICES AS NECESSARY. THE FIRE ALARM PROVIDER IS TO ADD ANY NEW DEVICES NEEDED TO PROVIDE A FULL SYSTEM PER LOCAL CODES. INSURE THE PRESENT DEVICES ARE IN LOCATIONS TO PROVIDE ADEQUATE COVERAGE.
2. LABEL THE BACK SIDE ALL JUNCTION BOX AND DEVICES COVER PLATES WITH THE CIRCUIT NUMBERS.
3. THE ELECTRICAL CONTRACTOR WILL BE CONNECTING THE ELEVATOR EQUIPMENT, ALL OF THE WIRING FOR THE ELEVATOR IS IN THE EQUIPMENT ROOM.
4. PROVIDE POWER FOR A SUMP PUMP IN THE ELEVATOR PIT.
5. INSTALL A RECEPTACLE AND VAPOR PROOF LIGHT IN THE ELEVATOR PIT AND AT THE TOP OF THE SHAFT PER LOCAL CODES. CURCUIT TO AN AVALIABLE CIRCUIT IN THE HOUSE PANEL.

1 / E2-3 ELECTRICAL CMC - LEVEL 2
1/8" = 1'-0"

Colorado Mountain College

PROJECT DESCRIPTION

Delta	Description	Date Issued
1	ADDENDUM #002	9/8/16

HUMPHRIES POLI ARCHITECTS

All reports, plans, specifications, computer files, field data, notes and other documents and instruments prepared by the Architect as instruments of service shall remain the property of the Architect. The Architect shall retain all common law, statutory and other reserved rights, including copyright thereto.

ELECTRICAL PLAN - CMC

BIDDING/PERMIT SET
8/01/2016

PROJECT No.	PROJECT ARCH	PROJECT MNGR	CHECKED BY
16-001	Approver	Designer	Checker

SHEET No.

E2-3

9/9/2016 1:50:47 PM